



Sacramento • Phone (916) 853-6280 • Fax (916) 853-6258
 Bay Area • Phone (925) 454-1363 • Fax (925) 454-1499
 11300 Sanders Drive, Suite #29 Rancho Cordova, CA 95742

PROJECT REPORT

I. SUMMARY:

UC Davis engaged the services of Apparatus Testing and Engineering, Inc. to provide maintenance testing and inspection of the electrical equipment at UC-Davis for the Raptor Area Enhancement Project. Testing was performed by Jeremy Gerds, NETA Certification #: 19-4-9345440, of Apparatus Testing and Engineering.

II. TEST EQUIPMENT USED:

- A. AEMC Megger
- B. AEMC TTR
- C. Megger DRLO

III. EQUIPMENT INSPECTED AND TESTED:

- A. One (1) Oil Filled Transformer.

IV. TEST PROCEDURES:

A. TRANSFORMERS - LIQUID FILLED

1. Visual and Mechanical Inspection
 - a. Inspect for physical damage, cracked insulators, leaks, tightness of connections and general mechanical and electrical conditions.
 - b. Verify proper auxiliary device operation.
 - c. Verify proper liquid level in all tanks.
 - d. Perform specific inspections and mechanical tests as recommended by manufacturer.
2. Electrical Tests
 - a. Perform insulation-resistance tests, winding-to-winding, and windings-to-ground. Test duration shall be for 10 minutes with resistance tabulated at 30 seconds, 1 minute and 10 minutes. Calculate dielectric absorption ratio and polarization index.
 - b. Perform a turns-ratio test between windings at all tap positions. The final tap setting is to be determined by the owner/user's electrical engineer and set by the testing firm.
 - c. Sample insulating liquid in accordance with ASTM D-923. Sample shall be laboratory tested for:
 1. Dielectric strength – ASTM D1816
 2. Acid Neutralization – ASTM D974
 3. Visual condition – ASTM D1524
 4. Interfacial tension – ASTM D971
 5. Dissolved gas analysis – ASTM D3612
 6. Water content – ASTM D1533B
 7. Specific gravity – ASTM D1298

8. Power factor: ASTM D-924
- d. Perform dissolved gas analysis (DGA) in accordance with ANSI/IEEE C57.104 or ASTM D-3612.
- e. Measure total combustible gas (TCG) content in accordance with ANSI/IEEE C57.104 or ASTM D-3284.
- h. Perform winding-resistance tests on each winding at all tap positions.

V. RESULTS AND RECOMMENDATIONS:


- A. Transformer was not installed at time of test. Client to verify grounding, anchoring, and conductor connections before energization.
- B. There may be a loose connection or improper torque on the well inserts affecting the resistance between well inserts H2A and H2B. It is recommended to verify proper torque on all well inserts before energization.
- C. A sample of the transformer's insulating fluid was taken and submitted to a lab for analysis.
 1. Oil lab results found elevated levels of acetylene, suggesting that arcing is possibly occurring within the transformer. This info, coupled with the higher internal resistance on H2 inserts, indicate a possible loose connection.
- D. This is a service-aged transformer and the acetylene may have been from previous use. A.T.E. has the following recommendations:
 1. If the application is low load and low priority, A.T.E. simply recommends a follow-up oil sample 6 months after energization to trend the oil results and decide if follow up work is required.
 2. If the application is considered vital or the load is expected to be high, the transformer should be repaired or replaced. It is unknown if this transformer is a totally welded tank or if it can be opened for inspection or repair.
- E. All other items tested passed NETA and/or Manufacturer's specifications.

DATA

TEST

SHEETS

TRANSFORMER TEST REPORT

CUSTOMER:				LOCATION:				JOB NO.: S-25001							
UNIVERSITY OF CALIFORNIA				RAPTOR CENTER				DATE: 3/6/25							
DAVIS, CA								TESTED BY: JG							
IDENTIFICATION: RAPTOR TRANSFORMER						TEST EQUIPMENT USED: AEMC MEGGER, AEMC TTR,									
						MEGGER DRLO									
NAMEPLATE INFORMATION				MEGGER TEST AT 5KVDC				ELECTRICAL TEST DATA							
MFG.	COOPER	X	OIL	H-L (G)	25.5K MΩ	TURNS RATIO TEST			CONNECTIONS						
KVA	100		DRY	H-G (L)	21.1K MΩ	TAP	PRI. VOLTS	CALC. RATIO	H _{1A} H _{2A} -X ₁ X ₂	H _{1A} H _{2A} -X ₂ X ₃	H _{1A} H _{2A} -X ₁ X ₃				
IMPEDANCE	2.5%			L-G (H)	6.90K MΩ @ 1KV	A	13094	54.56 / 109.11	109.09	109.10	54.55				
SERIAL NO.	0852020790			DURATION: 1 MIN		B	12782	53.26 / 106.51	106.50	106.51	53.26				
OIL SAMPLE TAKEN	X	YES		NO	TEMP °C	13	AIR	13	OIL	C	12470	51.96 / 103.92	103.92	103.93	51.96
OIL CAPACITY	69 GAL	DGA#	S-103415			WINDING RESISTANCE (1)			D	12158	50.66 / 101.32	101.34	101.34	50.67	
PRIMARY VOLTAGE	12470V				H _{1A} -H _{2A}	11.53 Ω	X ₁ -X ₂	1904 μΩ	E	11847	49.36 / 98.72	98.76	98.76	49.38	
SECONDARY VOLTAGE	240V / 120V						X ₂ -X ₃	1110 μΩ	HIGH SIDE BUSING RESISTANCE (μΩ) (1,3)			H _{1A} - H _{1B}	H _{2A} - H _{2B}		
AS LEFT TAP	C (12470V)						X ₁ -X ₃	2825 μΩ				615	9712		
DIAGRAM:						VISUAL INSPECTION									
						BUSHINGS	OK	FANS	N/A	TEMP. GAUGE	OK				
						INSULATORS	OK	CONTROL WIRING	N/A	LIQ. LEVEL GAUGE	OK				
						CONNECTIONS	(2)	GROUNDING	(2)	PRESS. GAUGE	N/A				
						ANCHORING	(2)	PRES. RELIEF DEV.	OK						
REMARKS:						DAR / PI DATA:		30S	60S	10M	DAR	PI			
(1) WINDING RESISTANCE TESTS PERFORMED AT NOMINAL TAP 12470V (C). VALUES						H - L (G)		19.1K	25.5K	65.9K	1.34	2.58			
CORRECTED TO 75°C FOR ALUMINUM WINDINGS, CORRECTION FACTOR 1.261.						H - G (L)		19.9K	21.1K	23.25K	1.06	1.10			
(2) XFMR NOT INSTALLED AT TIME OF TEST.						L - G (H)		5.20K	6.90K	10.58K	1.33	1.53			
(3) THE BUS RESISTANCE FROM H2A TO H2B IS SIGNIFICANTLY HIGHER THAN H1A TO H2A. IT IS RECOMMENDED TO VERIFY TORQUE ON ALL WELL INSERTS BEFORE ENERGIZATION.															

TRANSFORMER WINDING RESISTANCE TEST REPORT

CUSTOMER:	LOCATION:	JOB NO.: S-25001
UNIVERSITY OF CALIFORNIA	RAPTOR CENTER	DATE: 3/6/25
DAVIS, CA		TESTED BY: JG

TRANSFORMER IDENTIFICATION: RAPTOR CENTER	TEST EQUIPMENT USED: MEGGER DRLO

TEST DATA

HIGH VOLTAGE WINDING	MEASURED WINDING RESISTANCE (Ω)			RESISTANCE CORRECTED TO 75°C (m Ω)			TEST SET SCALE	DURATION	REMARKS
	H _{1A} -H _{2A}		H _{1B} -H _{2B}	H _{1A} -H _{2A}		H _{1B} -H _{2B}			
A (13094V)	9.144		9.153	11.531		11.542	2.5 Ω	1 MIN	(1)
B (12782V)	8.919		8.925	11.247		11.254	2.5 Ω	1 MIN	(1)
C (12470V)	8.702		8.709	10.973		10.982	2.5 Ω	1 MIN	(1)
D (12158V)	8.495		8.490	10.712		10.706	2.5 Ω	1 MIN	(1)
E (11847V)	8.354		8.361	10.534		10.543	2.5 Ω	1 MIN	(1)
LOW VOLTAGE WINDING	MEASURED WINDING RESISTANCE ($\mu\Omega$)			RESISTANCE CORRECTED TO 75°C ($\mu\Omega$)			TEST SET SCALE	DURATION	REMARKS
	X ₁ -X ₂	X ₂ -X ₃	X ₁ -X ₃	X ₁ -X ₂	X ₂ -X ₃	X ₁ -X ₃			
240V / 120V	1510	880	2240	1904	1110	2825	25 m Ω	1 MIN	(1)

REMARKS:
(1) TEMPS CORRECTED TO 75°C FOR ALUMINUM WINDINGS. WINDING TEMP AT TIME OF TEST 13C, 68% HUMIDITY, CORRECTION FACTOR 1.261.

Lee Madsen
Apparatus Testing & Engineering

11300 Sanders Drive Ste 29
Rancho Cordova, CA 95742

Location : UCD-RAPTOR
Bank & Phase :
Serial Number : 0852020790
Manufacturer : Cooper
Equipment Type : Transformer
Model :

Date : 03-19-2025
Report Number : 1415667
P.O. Number: S-25001
Year of Mfg. :
kV Rating : 12.47
Breathing :
Cooling :
Fluid type : Natural Ester
Fluid Volume :

Sample Date :	3/6/2025
Laboratory No. :	1415667
Container No. :	S-103415
Temperature :	13
Hydrogen (ppm) :	24
Methane (ppm) :	5
Ethane (ppm) :	102
Ethylene (ppm) :	14
Acetylene (ppm) :	4
Carbon monoxide (ppm) :	43
Carbon dioxide (ppm) :	1695
Nitrogen (ppm) :	30512
Oxygen (ppm) :	379
Total (ppm) :	32778
Total (%) :	3.28
TDCG (ppm) :	192
TDCG Rate (ppm/day) :	0.0
ETCG (% in blanket) :	0.23
CH ₄ / H ₂ :	0.19
C ₂ H ₂ / C ₂ H ₄ :	0.30
C ₂ H ₂ / CH ₄ :	0.88
C ₂ H ₆ / C ₂ H ₂ :	24.39
C ₂ H ₄ / C ₂ H ₆ :	0.13
CO ₂ / CO :	39.09
O ₂ / N ₂ :	0.01

Dissolved Gas Diagnostics

Key Gas Method : Arcing is indicated.

Ethane is being produced as a byproduct of oxidation.



Dissolved Gas Analysis

ASTM D3612-C

Lee Madsen
Apparatus Testing & Engineering

11300 Sanders Drive Ste 29
Rancho Cordova, CA 95742

Location : UCD-RAPTOR
Bank & Phase :
Serial Number : 0852020790
Manufacturer : Cooper
Equipment Type : Transformer
Model :


Date : 03-19-2025
Report Number : 1415667
P.O. Number: S-25001
Year of Mfg. :
kV Rating : 12.47
Breathing :
Cooling :
Fluid type : Natural Ester
Fluid Volume :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'Tyler Harris-Krull', written over a horizontal line.

Tyler Harris-Krull
Laboratory Manager



ANALYTICAL SERVICES

Insulating Fluid Evaluation

Lee Madsen
Apparatus Testing & Engineering

11300 Sanders Drive Ste 29
Rancho Cordova, CA 95742

Location : UCD-RAPTOR
Bank & Phase :
Serial Number : 0852020790
Manufacturer : Cooper
Equipment Type : Transformer
Model :
Year of Mfg. :

Date : 03-19-2025
Report Number : 1415667
P.O. Number : S-25001
kV Rating : 12.47
Breathing :
Cooling :
Fluid type : Natural Ester
Fluid Volume :

Sample Date : 3/6/2025
Laboratory Number : 1415667
Container Number : S-103415
Temperature : 13
D1533 Moisture (ppm) : 49
D971 Interfacial Tension (mN/m) : 29.0
D974 Acid Number (mg KOH/g) : 0.04
D1500 Color Number (ASTM) : <1.0
D1524 Visual Examination : Clear w/ part.
D877 Dielectric BV (kV) :
D1816 Dielectric BV (kV) : 24
D924 Power Factor (% at 25 C) : 0.221
D924 Power Factor (% at 100 C) :
D2668 Oxidation Inhibitor (%) :
D1298 Specific Gravity : 0.919
D445 Viscosity (SUS) :
D97 Pour Point (C) :
D92 Flash Point (C) :
D92 Fire Point (C) :
D1807 Refractive Index :
D1275 Corrosive Sulfur :

Insulating Fluid Diagnostics

	ASTM D6871	IEEE Group I	
Moisture :	200 max	Acceptable	35 max
Interfacial Tension :		Acceptable	24 min
Acid Number :		Acceptable	0.2 max
Color Number :	10. max		
Visual Examination :	clear & bright		
Dielectric BV D877 :		Acceptable	26 min
Dielectric BV D1816 :	20 min		23 min
Power Factor @ 25 C :	0.20 max		
Power Factor @ 100 C :	4.0 max		
Oxidation Inhibitor :			
Specific Gravity :	0.96 max		
Viscosity @ 40 C :	230 max		
Pour Point :	10 max		
Flash Point :	275 min		
Fire Point :	145 min		
Refractive Index :			
Corrosive Sulfur :	noncorrosive		

Comments :



Insulating Fluid Evaluation

Lee Madsen
Apparatus Testing & Engineering

11300 Sanders Drive Ste 29
Rancho Cordova, CA 95742

Location : UCD-RAPTOR
Bank & Phase :
Serial Number : 0852020790
Manufacturer : Cooper
Equipment Type : Transformer
Model :
Year of Mfg. :

Date : 03-19-2025
Report Number : 1415667
P.O. Number : S-25001
kV Rating : 12.47
Breathing :
Cooling :
Fluid type : Natural Ester
Fluid Volume :

TJ|H2b Analytical Services issues reports in a simplified manner; not all ASTM and ISO/IEC 17025 requirements are addressed in this report; however, all required information is retained and available upon request. TJ|H2b does not perform sampling services and provides results for tests performed on samples as received. TJ|H2b assumes no responsibility for the quality or condition of the samples it receives or for the accuracy of any information provided with those samples. Test reports shall not be reproduced, except in full, without prior written consent of TJ|H2b.

Approved by:

A handwritten signature in black ink, appearing to read 'Tyler Harris-Krull', written over a horizontal line.

Tyler Harris-Krull
Laboratory Manager