



Electrical Requirements

Single Bike Unit



Required Electrical Outlet

Receptacle: Regular household outlet
Style: 15 Amps
Range: 110 - 125V
Unit will draw: 11 Amps
Wire: 14/2 (black, white, ground)

Double Bike Unit



Required Electrical Outlet

Receptacle: NEMA Code - L14-20R
Style: 20 Amp 4-pin Twist Lock
Range: 208 - 250V
Unit will draw: 12 Amps
Wire: 12/3 (red, black, white, ground)

Three/Four Bike Unit



Required Electrical Outlet

Receptacle: NEMA Code - L14-30R
Style: 30 Amp 4-pin Twist Lock
Range: 208 - 250V
Unit will draw: 15-16 Amps
Wire: 10/3 (red, black, white, ground)

Receptacle Placement

- For "renovations" or "new construction" the optimal receptacle height should be 82" from finished flooring, centered above Decon Unit.
- For existing buildings the cord length supplied with the Decon Unit will reach 12" to either side of the Unit for code height wall receptacles.