


Test Data

Kunde	Coro-Foods			Lokal Nr.	PA-26
Fabrikat	Alfa Laval	Type	C8-SR	Serie	30106-09457
Unit ID.		Measure	1481 mm	Rapport nr.	300102

			Section	Prod./Media	Tryk/Bar		
Dato	12-10-2009	1	1	M	1,09	->	1,06
Tid	13:37:50	2	1,2	P	5,40	->	5,26
Test tid	30 min.	3	3,4	P	1,02	->	1,01
		4	2	P	1,22	->	1,22
Tekniker	PS - HM	5	3	P	4,65	->	4,43
		6	4	M	5,25	->	5,22

Tryk/Bar



kommentar

Tryk 1 = sek. 1 - Damp
Tryk 2 = sek. 1 og 2 - vand cirkul.
Tryk 3 = sek. 3 og 4 - produkt regenerativ og køling
Tryk 4 = sek. 2 - opvarmning produkt
Tryk 5 = sek. 3 - regenerativ
Tryk 6 = sek. 4 - Isvand
ALT OK