

Potential Asbestos Containing Materials Summary

The St. Ann School

<i>Sample ID</i>	<i>Location</i>	<i>Material Description</i>	<i>ACM</i>	<i>Friable/Non Friable</i>	<i>Type of Asbestos</i>	<i>Percentage Asbestos</i>	<i>Estimated Quantity</i>	<i>Remarks</i>
ANN-1A	Classroom #5	Drywall joint compound	Yes	Non-friable	Chrysotile	2%	Unknown	Throughout institution
ANN-1B	Classroom #8	Drywall joint compound	Yes	Non-friable	Chrysotile	2%	Unknown	Throughout institution
ANN-1C	Classroom #7	Drywall joint compound	Yes	Non-friable	Chrysotile	2%	Unknown	Throughout institution
ANN-1D	Classroom #3	Drywall joint compound	Yes	Non-friable	Chrysotile	2%	Unknown	Throughout institution
ANN-1E	Secretary's office	Drywall joint compound	No	-	-	-	-	Considered ACM due to previous results
ANN-1F	Classroom #2A	Drywall joint compound	No	-	-	-	-	Considered ACM due to previous results
ANN-1G	Mechanical room	Drywall joint compound	No	-	-	-	-	Considered ACM due to previous results
ANN-2A	Boiler room	Ceiling stucco	No	-	-	-	-	
ANN-2B	Boiler room	Ceiling stucco	No	-	-	-	-	
ANN-2C	Boiler room	Ceiling stucco	No	-	-	-	-	
ANN-3A	Meeting room	24x48" textured ceiling tile	No	-	-	-	-	
ANN-3B	N/A	No sample	No	-	-	-	-	
ANN-3C	N/A	No sample	No	-	-	-	-	
ANN-4A	N/A	No sample	No	-	-	-	-	
ANN-4B	N/A	No sample	No	-	-	-	-	

Potential Asbestos Containing Materials
Summary

St. Ann School
Sault Ste. Marie, Ontario

ANN-4C	N/A	No sample	No	-	-	-	-	
ANN-5A	N/A	No sample	No	-	-	-	-	
ANN-5B	N/A	No sample	No	-	-	-	-	
ANN-5C	N/A	No sample	No	-	-	-	-	
ANN-6A	Classroom #7	12x12" fibreboard ceiling tile	No	-	-	-	-	
ANN-6B	Classroom #7	12x12" fibreboard ceiling tile	No	-	-	-	-	
ANN-6C	Classroom #7	12x12" fibreboard ceiling tile	No	-	-	-	-	
ANN-7A	Classroom #5	12x12" beige marble vinyl floor tile	Yes	Non-friable	Chrysotile	2%	500 ft ²	
ANN-7B	Classroom #5	12x12" beige marble vinyl floor tile	Yes	Non-friable	Chrysotile	2%	-	
ANN-7C	Classroom #5	12x12" beige marble vinyl floor tile	Yes	Non-friable	Chrysotile	2%	-	
ANN-8A	Classroom #8	12x12" brown marble vinyl floor tile	Yes	Non-friable	Chrysotile	3%	2,450 ft ²	Also in caretaker's room, principal's office, classroom #2, and library
ANN-8B	Classroom #8	12x12" brown marble vinyl floor tile	Yes	Non-friable	Chrysotile	3%	-	Same as above
ANN-8C	Classroom #8	12x12" brown marble vinyl floor tile	Yes	Non-friable	Chrysotile	3%	-	Same as above

December 2007

Potential Asbestos Containing Materials
Summary

St. Ann School
Sault Ste. Marie, Ontario

ANN-9A	Caretaker's room	Cloth wrap pipe insulation with fiberglass	No	-	-	-	-	
ANN-9B	Caretaker's room	Cloth wrap pipe insulation with fiberglass	No	-	-	-	-	
ANN-9C	Equipment room	Cloth wrap pipe insulation with fiberglass	No	-	-	-	-	
ANN-10A	Caretaker's room	Pipe joint insulation	Yes	Friable	Chrysotile	40%	TMTQ	Also observed in classrooms, corridor #2, equipment storage room, and gymnasium stage/storage,
ANN-10B	Caretaker's room	Pipe joint insulation	Yes	Friable	Chrysotile	60%	-	Same as above
ANN-10C	Caretaker's room	Pipe joint insulation	No	-	-	-	-	Considered ACM due to previous results
ANN-11A	Equipment room	8x8" white vinyl floor tile	Yes	Non-friable	Chrysotile	3-7%	150 ft²	
ANN-11B	Equipment room	8x8" white vinyl floor tile	Yes	Non-friable	Chrysotile	3-7%	-	
ANN-11C	Equipment room	8x8" white vinyl floor tile	Yes	Non-friable	Chrysotile	3-7%	-	
ANN-12A	Secretary's office	Blue sheet vinyl flooring	No	-	-	-	-	
ANN-12B	Secretary's office	Blue sheet vinyl flooring	No	-	-	-	-	
ANN-12C	Secretary's office	Blue sheet vinyl flooring	No	-	-	-	-	

December 2007

Potential Asbestos Containing Materials
Summary

St. Ann School
Sault Ste. Marie, Ontario

ANN-13A	Classroom #4	9x9" light brown vinyl floor tiles	Yes	Non-friable	Chrysotile	3-10%	450 ft ²	
ANN-13B	Classroom #4	9x9" light brown vinyl floor tiles	Yes	Non-friable	Chrysotile	3-10%	-	
ANN-13C	Classroom #4	9x9" light brown vinyl floor tiles	Yes	Non-friable	Chrysotile	3-10%	-	
ANN-14A	Classroom #3	9x9" dark brown vinyl floor tiles	Yes	Non-friable	Chrysotile	10%	400 ft ²	
ANN-14B	Classroom #3	9x9" dark brown vinyl floor tiles	Yes	Non-friable	Chrysotile	10%	-	
ANN-14C	Classroom #3	9x9" dark brown vinyl floor tiles	Yes	Non-friable	Chrysotile	10%	-	
ANN-15A	Classroom #2A	12x12" light brown vinyl tile	No	-	-	-	-	
ANN-15B	Classroom #2A	12x12" light brown vinyl tile	No	-	-	-	-	
ANN-15C	Classroom #2A	12x12" light brown vinyl tile	No	-	-	-	-	
ANN-16A	Corridor #1	Grey sheet vinyl flooring	No	-	-	-	-	
ANN-16B	Corridor #1	Grey sheet vinyl flooring	No	-	-	-	-	
ANN-16C	Corridor #1	Grey sheet vinyl flooring	No	-	-	-	-	

TMTQ = Too Many To Quantify
NT - NOT TESTED

December 2007